

Project Washington State Penitentiary Wall Restoration Job No. W8033-62
 Client Washington State Department of Corrections
 Prime Contractor Johnson Western Gunite
 Subcontractor _____
 Report to Wash State Dept of Corrections, P.O. Box 41112, Olympia WA 98504-1112, Johnson Western Gunite, SCM Consultants
 Concrete placed in north wall at east handball court

MATERIALS AND MIX DATA

Concrete Supplier Koncrete Industries Mix No. _____
 Type and Brand of Cement Lafarge Sacks/cu.yd. 7.0
 Admixtures - Kind and Amount 1. Kelcrete 2. _____
 Water Source well Max Aggregate Size 3/8" Req'd Strength @ 28 days 4000P.S.I.

FIELD TEST DATA

Truck No. M5 Slump 2" Cast By Scott Hall
 Ticket No. 3783 Air Content 6.5% Weather Cloudy/Windy
 Time Batched _____ Conc. Temp. 63° Date Cast 11/08/94
 Time Cast 12:15 p.m. Air Temp 46° Date in Lab 11/11/94
2 truck of 4 trucks w/ 10 cu.yds on truck and a total pour of 40 cu yds.
 Concrete Curing Temperature Extremes: High _____ Low _____
 Field data by: X APA _____ Client/Cylinder delivered to lab by: X APA _____ Client

SPECIMEN TEST DATA

Cylinder Size: X 6" x 12" Surface Area: _____ 28.27 sq.in.

Cylinder No.	Client I.D. No.	Date Tested	Age-Days	Total Load Lbs.	Compressive Str. P.S.I.	Date Reported	Copies Sent
1759-01		11/15/94	7	95,000	3370	11/15/94	3
1759-02		12/06/94	28	142,000	5020	12/06/94	3
1759-03		12/06/94	28	145,500	5150	12/06/94	

Remarks:

ANDERSON-PERRY & ASSOCIATES, INC.

By Wayne L. Couture
 Wayne L. Couture, S.E.T.
 Laboratory Supervisor

File No. W8033-60-81 (Wall)

ENGINEERING

SURVEYING

MATERIALS TESTING

1801 Fir St., P.O. Box 1107
 La Grande, Oregon 97850-0808
 (503) 983-8308 - Fax (503) 983-8468

214 E. Birch, P.O. Box 1687
 Waukegan, WA 98362-0032
 (509) 529-8200 - Fax (509) 529-8102

6309 2nd St., P.O. Box 1608
 Lewiston, Idaho 83601-2164
 (208) 748-8375