

ROBERT L. NELSON & ASSOCIATES, INC.

CONSTRUCTION MATERIALS LABORATORY

1107 TOWER ROAD

SCHAUMBURG, ILLINOIS 60173

708/882-1146

Kellert Industries
Kel-Crete Sample A Type M
August 17, 1992
Page 3

FLEXURAL BOND STRENGTH (ASTM C1072) (Continued)

Average PSI:	169.8
Standard deviation:	11.31
COV:	6.66%
Corrected PSI:	155.4

Respectfully submitted,

ROBERT L. NELSON & ASSOCIATES, INC.

Robert L. Nelson
President

RLN/jn